



**City of Tampa**

*Jane Castor, Mayor*

**Contract Administration**  
**Michael W. Chucran, Director**

306 East Jackson Street, 4N  
Tampa, FL 33602

Office (813) 274-8116  
Fax: (813) 274-7368

**ADDENDUM 3**

**Via E-Mail**

**DATE: February 24, 2023**

Contract: 22-C-00044; Hyde Park Groundwater Diversion Underdrains

Bidders on the above-referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

1. The bid opening date is hereby changed to March 7, 2023.
2. In Specific Provisions SP-16 Dewatering, on page SP-3, paragraph 3, delete the fifth sentence that begins with 'Because the construction site...' in its entirety and replace it with the following sentence:

"For construction areas within or adjacent to residential areas, day-night average sound levels from dewatering pumps shall be limited to 65dB(A) by the use of a noise abatement enclosure or other approved noise abatement system."

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect. Questions are to be e-mailed to [ContractAdministration@tampagov.net](mailto:ContractAdministration@tampagov.net).

*Jim Greiner*

Jim Greiner, P.E., Contract Management Supervisor