

Contract Administration Richard Mutterback, Director

306 East Jackson Street, 4N Tampa, FL 33602

> Office (813) 274-8116 Fax: (813) 274-7368

ADDENDUM 2 Via E-Mail DATE: November 30, 2023

Contract: 23-C-00026; HFC AWTP FSTs 1-6 Process Air Piping Replacement

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

Item 1: The bid opening date is hereby changed to December 12, 2023.

Item 2: The Specifications require the pipe and fittings to be 316 Stainless Steel but it does not specify seamless or welded. Is welded pipe acceptable? ASTM A312 Type 316 Welded - Either seamless or welded pipe are acceptable.

Item 3: Will standard wall thickness of 0.375" be acceptable for the 12" pipe size in lieu of True Sch 40 -0.046? 0.375" will be a heavier wall thickness than any of the other pipe sizes. - Schedule 40 Type 316L Stainless Steel pipe shall be provided.

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect. Questions are to be e-mailed to ContractAdministration@tampagov.net.

him Greiner

Jim Greiner, P.E., Contract Management Supervisor

	tampagov.net	
--	--------------	--