

ADDENDUM 2

DATE: June 16, 2026

Contract: 26-C-00024; HFC AWTP FSTs No. 1-6 Inlet Baffle Replacement

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

Item 1 – On Contract Drawing Sheet 9 Inlet Baffle Details, Section A-A and Detail A, Identify the 5 x 5 tube steel as ¼” wall thickness; Section B-B – Identifies the 5 x 5 tube steel as 3/8” wall thickness.

Response: The correct thickness is 1/4”.

Item 2 – Attached is the sign-in sheet for the site visit held on June 9, 2026.

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect. Questions are to be e-mailed to ContractAdministration@tampagov.net.

Jim Greiner, P.E., Contract Management Supervisor

