ADDENDUM 2
DATE: June 16, 2026

Contract: 26-C-00024; HFC AWTP FSTs No. 1-6 Inlet Baffle Replacement

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

Item 1 – On Contract Drawing Sheet 9 Inlet Baffle Details, Section A-A and Detail A, Identify the 5 x 5 tube steel as ¼" wall thickness; Section B-B – Identifies the 5 x 5 tube steel as 3/8" wall thickness.

Response: The correct thickness is 1/4".

Item 2 – Attached is the sign-in sheet for the site visit held on June 9, 2026.

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect. Questions are to be e-mailed to ContractAdministration@tampagov.net.

Jim Greiner, P.E., Contract Management Supervisor

26-C-00024 | HFC AWTP FSTs No. 1-6 Inlet Baffle Replacement			
Subject:	Site Visit / Walkthrough	**Meeting Date:**	Tuesday June 9th, 2026
City of Tampa	Wastewater Department	**Time:**	9:00am – 10:00am

Name	Organization	E-Mail
Karloren Guzman	COT Wastewater	Karloren.Guzman@tampagov.net
Jack Ferras	COT Wastewater	Jack.Ferras@tampagov.net
Joel Dickson	COT wastewater	Joel.Dickson@tampagov.net
Bob Terrell	Pro Serv	rterrell@psicllc.com
Anthony Presutti	Razorback LLC	Anthony@RazorbackLLC.com
Mark Johnson	COT/CAD	Mark.Johnson@Tampagov.net