



# CITY OF TAMPA

Bob Buckhorn, Mayor

CONTRACT ADMINISTRATION DEPARTMENT

David L. Vaughn, AIA, Director

## ADDENDUM NO. 1

**DATE: October 2, 2013**

Contract 14-C-00003; Downtown Gateway Lighting Improvements at Franklin Street and Jefferson/Orange Street at I-275 – Sheltered Market

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

**Item 1: Volume 2; Sheets L-5, L-9,** Load Center shown on Sheet L-5 that is to be located inside existing building needs to be relocated to an exterior location Northeast of the pull box located near N. Orange Street. Configuration of Load Center and new panel board, conduits, contactor and other related electrical component are shown on Sheet L-5, Service Point Schematic Diagram. All components to be properly mounted and housed in NEMA rated enclosure(s).

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect. Questions are to be e-mailed to Contract Administration@tampagov.net.

*Jim Greiner*

Jim Greiner, P.E., Contract Management Supervisor