



CITY OF TAMPA

Bob Buckhorn, Mayor

CONTRACT ADMINISTRATION DEPARTMENT

David L. Vaughn, AIA, Director

ADDENDUM NO. 3

DATE: November 26, 2013

Contract 14-C-00006; Lake Eckles Pump Station and Force Main Replacement

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

Item 1: The bid date is hereby changed to December 10, 2013.

Item 2: Temporary Pumping

The Contractor is responsible to provide temporary pumping capacity to keep the lake level below the critical elevation to prevent flooding of structures at such time when the current pump is out of service. The existing pump has a capacity of 1200 gpm. The head loss is 50 feet, plus static head due to water level differential. It has been calculated to require 250 hours to lower the lake 2 feet at 1200 gpm. The critical stage for the lake before structure flooding occurs is 33.6

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect. Questions are to be e-mailed to Contract Administration@tampagov.net.

Jim Greiner

Jim Greiner, P.E., Contract Management Supervisor