



CITY OF TAMPA

Bob Buckhorn, Mayor

CONTRACT ADMINISTRATION DEPARTMENT

David L. Vaughn, AIA, Director

ADDENDUM NO. 1

DATE: March 31, 2015

CONTRACT 15-C-00016; FIRE STATION NO. 1 PARKING GARAGE STRUCTURAL CONCRETE REPAIR

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

- Item 1: Specifications, Supplementary General Provisions, paragraph 2.1 – Section 1 Scope and Intent: **CLARIFICATION** that the City will bear the cost related to City issued permits.
- Item 2: Specifications, Supplementary General Provisions, paragraph 2.4 – Section 5 Inspection and Testing: **CLARIFICATION** to General Provisions paragraph G-5.01 and G-5.02 that the City will provide testing of materials related to soil density and concrete strength only.
- Item 3: Specifications, Section 03312-3.06: **CLARIFICATION** that quantity of concrete repairs (3,600 LF of cracks; also, 150 SF of spalls, including 50 SF related to the weld plates) is based on approximate locations and areas shown on the Drawings (including, but not limited to Sheet No's. S200, S202, S203, S300, S301, and S302) and shall be included in the Base Bid.
- Item 4: Specifications, Section 03720-1.01B: **CLARIFICATION** that quantity of concrete resurfacing (3,000 SF) is based on approximate locations and areas shown on the Drawings (including, but not limited to Sheet No. S202) and shall be included in the Base Bid.
- Item 5: Specifications, Section 09900-1.01: **CLARIFICATION** that quantity of exterior coating (1,650 SF) is based on approximate locations and areas shown on the Drawings (including, but not limited to Sheet No's. S300 and S301) and shall be included in the Base Bid.

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect. Questions are to be e-mailed to Contract Administration@tampagov.net.

Jim Greiner

Jim Greiner, P.E.,
Contract Management Supervisor

306 E. Jackson Street, 4N • Tampa, Florida 33602 • (813) 274-8456 • FAX: (813) 274-8080


www.tampagov.net