



# CITY OF TAMPA

Bob Buckhorn, Mayor

Contract Administration Department

Michael W. Chucran, Director

## ADDENDUM 3

September 4, 2018

### Contract 15-C-00044; Louisiana Pump Station Rehabilitation

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

Item 1: A site visit will be conducted at 10 AM Thursday September 6, but questions will NOT be entertained.

Item 2: Instructions to Bidders, page I-1b: Change, in I-1.05 Time For Completion "360" to read "660".

Item 3: Plan Sheet E-3, Note 20; add the following to the note: "Unless otherwise noted, existing conduits not scheduled for reuse shall be removed to the floor, ceiling or wall and discarded. All resulting voids or damage shall be patched to match existing surface".

Item 4: Plan Sheet E-3, Note 21 a; add the following to the note: "The Contractor shall be responsible for supplying, installing and maintaining all required equipment; and covering all energy costs during construction."

Item 5: Electrical Plan Sheet E-3, Note 16: revise first sentence to read: "The existing bubbler/pump control cabinet, located on the upper level of the pump station shall be replaced as indicated on the drawings."

Item 6: Structural Plans: Sheet S1.0: General Structural Notes – under Building Codes and Specifications note 1. revise note 1 to read: "...6th Edition (2017) and Chapter 5 of the City of Tampa Code."

Item 7: Specific Provision SP-33 Fences, modify sentence to read: "Temporary fences, where required, shall be chain-link fence or other suitable fencing as approved by the Engineer."

Item 8: Structural Specification: Section 04200 Unit Masonry, 1.3 Submittals – Revise the first sentence to read: "In compliance with General Provisions and as specified herein."

Item 9: Structural Specification: Section 04230 Reinforced Unit Masonry, 1.3 Submittals – Revise the first sentence to read: "In compliance with General Provisions and as specified herein."

Item 10: Structural Specification: Section 05120 Structural Steel, 1.3 Submittals – Revise the first sentence to read: "In compliance with General Provisions and as specified herein."

Item 11: Architectural Specification: Section 09 91 00 Architectural Painting, 3.06 Inspection and Sample, D – Revise the first sentence to read: “The Contractor will engage the services...”.

Item 12: Clarifications in response to additional questions regarding the Equal Business Opportunity Program;

Forms MBD 10&20 must be submitted with the bid, refer to GFECF Form 50 Instructions – #s 1,3,5,7. Also refer to Bid Document Specifications page I-1C: Instruction To Bidders Section 1, Special Instructions (I-1.10 Equal Opportunity Program Subcontract Goals) regarding mandatory/minimum timeframe for soliciting subcontractors/suppliers.

Clarification: MBD Form-20 is a universal format. U-WMBE is a derivative of WMBE. The “U” is applied to companies deemed underutilized per MBD Form 70 included in bid specifications. Concerning 15-C-00044, it shall mean any company certified by COT as WMBE-African American (a/k/a BBE), and will be tagged as “U” and will count toward goal attainment. The minimum contact list highlights underutilized companies. The on-line directory denoted in the bid specifications can be queried by certification type, ethnicity, gender, trade, company name, et cetera; hence bidder can determine who else may be underutilized. The DMI 20 Form is multi-purposed... all subcontractors/suppliers ‘to-be-utilized’ must be reported as a value; total SLBEs as a value; total WMBEs as a value; and finally, total WMBEs as a percent of the total bid amount and SLBEs same. Companies that meet the U-WMBE designation shall be confirmed/calculated by the bidder (City validates) to determine the percent of goal achievement. Non-UMBE participation is reported as “Ancillary” by the City. Although ancillary participation is encouraged/expected, it will not be credited toward meeting the narrowly-tailored goal, but it may count toward overall project participation if compliance with GFECF is met for the underutilized group, or the U-WMBE goal is attained.

Clarification; A supplier who is certified by City of Tampa and operates as a ‘commercially useful function’ will count 100%. The MBD Office will determine if the supplier function complies with EBO Program standards.

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect. Questions are to be e-mailed to [ContractAdministration@tampagov.net](mailto:ContractAdministration@tampagov.net).

*Jim Greiner*

Jim Greiner, P.E. Contract Management Supervisor