



CITY OF TAMPA

Bob Buckhorn, Mayor

Contract Administration Department

Michael W. Chucran, Director

ADDENDUM 2

February 1, 2019

Contract 19-C-00004 Arc Flash Equipment Labeling at Wastewater Facilities

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

Item 1: Replace Specifications Section 26 05 73.17 - Arc Flash Risk Assessment / Short Circuit / Coordination Study item 1.7 with the following:

1.7 Computer Analysis Software: The studies shall be performed using SKM Systems Analysis Power Tools for Windows (PTW) software program. Contractor shall provide an electronic back-up copy of the SKM project files and folders upon project completion.

Item 2: I-1.05 TIME FOR COMPLETION: In the second paragraph, first line, Change "180" to be "365".

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect. Questions are to be e-mailed to ContractAdministration@tampagov.net.



Jim Greiner, P.E. Contract Management Supervisor

306 E. Jackson Street, 4N • Tampa, Florida 33602 • (813) 274-8456 • FAX: (813) 274-8080

