CITY OF TAMPA

Bob Buckhorn, Mayor **CONTRACT ADMINISTRATION DEPARTMENT**

Michael W. Chucran, Director

ADDENDUM 1

DATE: January 30, 2019

Contract 19-C-00004; Arc Flash Equipment Labeling at Wastewater Facilities

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

Item 1: The Bid Opening date for this project is hereby changed to February 19, 2019

Item 2: Replace Specifications Section 26 05 73.17 - Arc Flash Risk Assessment / Short Circuit / Coordination Study item 3.3 with the following:

3.3 Arc Flash Training:

The Contractor shall provide a total of sixteen (16) hours of training to the Owner's qualified electrical personnel of the potential arc flash hazards associated with working on energized equipment. The trainer shall be an authorized OSHA Outreach instructor.

The training shall provide for:

a. Two (2) sessions of training (16 hrs/session);
b. Each training day shall consist of eight (8) hours;
c. Eight (8) people per session. A total of sixteen (16) employees shall be trained.
d. At least sixteen (16) National Fire Protection NFPA 70E printed manuals shall be provided.

1. The training shall take place at the Howard F. Curren AWTP Maintenance Building Training Room.

2. The training shall include specific arc flash boundaries and distances for the equipment at the wastewater facilities designated in Attachments A1, A2 and A3.

Item 3: Clarification - The bidder must be properly Licensed by the State of Florida to conduct Contracting or Engineering and registered as a corporation with the Department of State. A bid from an electrical contracting firm is expected, but a properly Florida licensed Engineering firm may bid.

Item 4: Clarification – In Section 26 05 73.17 ARC FLASH RISK ASSESSMENT / SHORT CIRCUIT / COORDINATION STUDY, the certification called for in 1.5 A. requires that the Contractor certify that the final report and drawings have been prepared in compliance with the specifications.

Item 5: Replace the Qualifications Submittal form with the attached Qualifications Submittal form.

Item 6: Attached is the pre-bid meeting sign-in sheet.

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect. Questions are to be e-mailed to Contract Administration@tampagov.net.

Jim Greiner

Jim Greiner, P.E., Contract Management Supervisor

QUALIFICATION SUBMITTAL
(Submit with Proposed Fee)
Arc Flash Risk Assessment

Contractor:_____
Florida License No.: _____

☐ Attach resumes of Technicians that will be involved with on-site data gathering.

☐ Attach a list, with a complete description, of five (5) arc flash risk assessments over the past three (3) years. Provide client name, contact person, contact person's email address and contact person's telephone number.

_____
Name

_____
Signature

_____
Title

_____
Company

_____
Date

Contract 19-C-00004; Arc Flash Equipment Labeling at Wastewater Facilities — Pre-Bid Conf. 1-22-19 10:30am

E-Mail to Register as a Plan Holder and E-Mail All Questions to ContractAdministration@tampagov.net

Sign-In Sheet ☐ Please Print — City of Tampa, Contract Administration Department

	Name	Organization	E-Mail OR Phone
1	Jody Gray	Tampa Contract Administration Dept.	jody.gray@tampagov.net
2	SAURIN PARIKH	ASTUTE ENGINEERING	contact@astuteng.com / 202-400-2004
3	John Leedy	Engineered Electric Services	JLEEDY@EESLLCFL.com
4	WALT DINSE	TAW	walt.dinse@tawinc.com
5	KENT CLEARWATERS	EEE	CLEARWATERS@ELECTENG.COM
6	Penny Juleff	Powell	Penny.Juleff@Powellind.com
7	Will Besonen	Powell / Polytech	will@polytechservices.com
8	Lashonda Green	COT / WW	lashonda.green@tampagov.net
9	Kevin Schelb	COT / AWTF	Kevin.Schelb@tampagov.net
10	Julio Lopez	COT / CAD	Julio.lopez@tampagov.net
11	Mark R Johnson	COT / CAD	Mark.Johnson@Tampagov.net
12	JACK FERRAS	COT / WW	JACK.FERRAS@TAMPAGOV.NET
13	Scott KING	HALLAM-ICS	sking@hallam-ics.com
14	Chris Wilson	SEL ENGINEERING SERV	chris-wilson@selinc.com
15	Amy Jones	Revere Control Systems, Inc	ajones@reverecontrol.com
16	BOB HALLMAN	EDI	BHALL@EDTI.COM
17	ROMAN KORCHAK	C.O.T WW	ROMAN.KORCHAK@TAMPAGOV.NET
18	Eric Knight	TAW	Eric-Knight@TAWINC.COM
19			
20			
21			
22			
23			
24			
25			
26			
27			
28			
29			
30			
31			
32			
33			
34			
35			
36			