



CITY OF TAMPA

Bob Buckhorn, Mayor

CONTRACT ADMINISTRATION DEPARTMENT

Michael W. Chucran, Director

ADDENDUM 3

DATE: January 16, 2019

Contract 19-C-00013; Lowry Park and Davis Island Seaplane Basin Park Dock Improvements

Bidders on the above referenced project are hereby notified that the following addendum is made to the Contract Documents. BIDS TO BE SUBMITTED SHALL CONFORM TO THIS NOTICE.

Item 1: Replace Specifications Section 35 51 13 –Floating Dock Systems, Part 3 – Execution, 3.4 Dock System Tolerances, b., 1., with the following:

1. Float Width: +/- 3 inches from nominal float width.

The concrete dock width may be increased beyond the +3-inch tolerance to meet performance (wind, wave, stability, vessel impact, etc.) requirements. It is not acceptable to decrease the width beyond the +3-inch tolerance.

Item 2: Replace Specifications Section 35 51 14 – Aluminum Floating Dock Systems, Part 3 – Execution, 3.3 Dock System Tolerances, B., 1., with the following:

1. Float Width: +/- 6 inches from nominal float width.

All other provisions of the Contract Documents and Specifications not in conflict with this Addendum shall remain in full force and effect. Questions are to be e-mailed to ContractAdministration@tampagov.net.

Jim Greiner

Jim Greiner, P.E., Contract Management Supervisor