



Any table located adjacent to an exit must be placed so the edge of the table is no less than 40 inches from the exit discharge. The exit discharge will include the width of the door, and alcove or recess, or any other portion of the exit. Any table located adjacent to a fire department sprinkler connection (FDC – not shown) must be placed so the edge of the table is 55 inches from the edge of the FDC.